

Detailed Latest Test Results

Test Status: All, Test Type: All



The Southern Pat Company Limited

Portable Appliance Test Engineers

Client: Mirage Disco	Site: North Cheam	Location: SM3 9UR		
Asset ID: 08001	Description: IEC POWER LEAD	User: SPCL SA003	Test Instrument: W02-0416	
Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
IEC Lead Continuity	18/10/2008	0.108	ohm	Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
IEC Lead Polarity	18/10/2008			Pass
Overall: Pass				
Asset ID: 08002	Description: IEC POWER LEAD	User: SPCL SA003	Test Instrument: W02-0416	
Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
IEC Lead Continuity	18/10/2008	0.12	ohm	Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
IEC Lead Polarity	18/10/2008			Pass
Overall: Pass				
Asset ID: 08003	Description: IEC POWER LEAD	User: SPCL SA003	Test Instrument: W02-0416	
Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
IEC Lead Continuity	18/10/2008	0.136	ohm	Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
IEC Lead Polarity	18/10/2008			Pass
Overall: Pass				
Asset ID: 08004	Description: AC POWER LEAD	User: SPCL SA003	Test Instrument: W02-0416	
Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	248	V	Information
Neutral Voltage	18/10/2008	8	V	Information
Touch Current	18/10/2008	< 0.07	mA	Pass
Overall: Pass				
Asset ID: 08005	Description: AC POWER LEAD	User: SPCL SA003	Test Instrument: W02-0416	
Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	249	V	Information
Neutral Voltage	18/10/2008	8	V	Information
Touch Current	18/10/2008	< 0.07	mA	Pass
Overall: Pass				
Asset ID: 08006	Description: 4G EXT LEAD	User: SPCL SA003	Test Instrument: W02-0416	
Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	247	V	Information
Neutral Voltage	18/10/2008	8	V	Information
Touch Current	18/10/2008	< 0.07	mA	Pass
Overall: Pass				
Asset ID: 08007	Description: 1G EXT LEAD	User: SPCL SA003	Test Instrument: W02-0416	
Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	249	V	Information
Neutral Voltage	18/10/2008	8	V	Information
Touch Current	18/10/2008	< 0.07	mA	Pass
Overall: Pass				
Asset ID: 08008	Description: 1G EXT LEAD	User: SPCL SA003	Test Instrument: W02-0416	
Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Earth Continuity	18/10/2008	0.13	ohm	Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	248	V	Information
Neutral Voltage	18/10/2008	8	V	Information
PE Conductor Current	18/10/2008	< 0.15	mA	Pass

Detailed Latest Test Results

Test Status: All, Test Type: All



The Southern Pat Company Limited

Portable Appliance Test Engineers

Overall: Pass

Asset ID: 08009	Description: 4G IEC EXT LEAD	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Live Voltage	18/10/2008	248	V Information
Neutral Voltage	18/10/2008	8	V Information
Touch Current	18/10/2008	< 0.07	mA Pass

Overall: Pass

Asset ID: 08010	Description: 4G EXT LEAD	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Live Voltage	18/10/2008	248	V Information
Neutral Voltage	18/10/2008	8	V Information
Touch Current	18/10/2008	< 0.07	mA Pass

Overall: Pass

Asset ID: 08011	Description: 1G EXT LEAD	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Live Voltage	18/10/2008	249	V Information
Neutral Voltage	18/10/2008	8	V Information
Touch Current	18/10/2008	< 0.07	mA Pass

Overall: Pass

Asset ID: 08012	Description: 1G EXT LEAD	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Live Voltage	18/10/2008	248	V Information
Neutral Voltage	18/10/2008	8	V Information
Touch Current	18/10/2008	< 0.07	mA Pass

Overall: Pass

Asset ID: 08013	Description: 1G EXT LEAD	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Live Voltage	18/10/2008	246	V Information
Neutral Voltage	18/10/2008	8	V Information
Touch Current	18/10/2008	< 0.07	mA Pass

Overall: Pass

Asset ID: 08014	Description: 1G EXT LEAD	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Live Voltage	18/10/2008	248	V Information
Neutral Voltage	18/10/2008	8	V Information
Touch Current	18/10/2008	< 0.07	mA Pass

Overall: Pass

Asset ID: 08015	Description: IEC POWER LEAD	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
IEC Lead Continuity	18/10/2008	0.17	ohm Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
IEC Lead Polarity	18/10/2008		Pass

Overall: Pass

Asset ID: 08016	Description: LIGHT CONTROL UNIT	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Live Voltage	18/10/2008	248	V Information
Neutral Voltage	18/10/2008	8	V Information

Detailed Latest Test Results

Test Status: All, Test Type: All



The Southern Pat Company Limited

Portable Appliance Test Engineers

Touch Current 18/10/2008 < 0.07 mA Pass
Overall: Pass

Asset ID: 08017	Description: LIGHT CONTROL UNIT	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Live Voltage	18/10/2008	247	V Information
Neutral Voltage	18/10/2008	8	V Information
Touch Current	18/10/2008	< 0.07	mA Pass
Overall: Pass			

Asset ID: 08018	Description: DENON MIX DESK	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Overall: Pass			

Asset ID: 08019	Description: LABGRUPPEN AMP	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Overall: Pass			

Asset ID: 08020	Description: LABGRUPPEN AMP	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Overall: Pass			

Asset ID: 08021	Description: LEM CROSS OVER UNIT	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Overall: Pass			

Asset ID: 08022	Description: 4G EXT LEAD	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Live Voltage	18/10/2008	246	V Information
Neutral Voltage	18/10/2008	8	V Information
Touch Current	18/10/2008	< 0.07	mA Pass
Overall: Pass			

Asset ID: 08023	Description: SUPER SCIMITAR LAMP	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Earth Continuity	18/10/2008	0.062	ohm Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Live Voltage	18/10/2008	247	V Information
Neutral Voltage	18/10/2008	8	V Information
PE Conductor Current	18/10/2008	< 0.15	mA Pass
Overall: Pass			

Asset ID: 08024	Description: SUPER SCIMITAR LAMP	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Earth Continuity	18/10/2008	0.052	ohm Pass
Insulation Resistance	18/10/2008	> 199	MOhm Pass
Live Voltage	18/10/2008	248	V Information
Neutral Voltage	18/10/2008	8	V Information
PE Conductor Current	18/10/2008	< 0.15	mA Pass
Overall: Pass			

Asset ID: 08025	Description: TRISTAR LAMP	User: SPCL SA003	Test Instrument: W02-0416
Test Type	Date	Result	Unit Status
Visual	18/10/2008		Pass
Earth Continuity	18/10/2008	0.052	ohm Pass

Detailed Latest Test Results

Test Status: All, Test Type: All



The Southern Pat Company Limited

Portable Appliance Test Engineers

Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	248	V	Information
Neutral Voltage	18/10/2008	8	V	Information
PE Conductor Current	18/10/2008	< 0.15	mA	Pass

Overall: Pass

Asset ID: 08026	Description: SKYRAY LAMP	User: SPCL SA003	Test Instrument: W02-0416
-----------------	--------------------------	------------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Earth Continuity	18/10/2008	0.17	ohm	Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	248	V	Information
Neutral Voltage	18/10/2008	8	V	Information
PE Conductor Current	18/10/2008	< 0.15	mA	Pass

Overall: Pass

Asset ID: 08027	Description: SPECTRE LAMP	User: SPCL SA003	Test Instrument: W02-0416
-----------------	---------------------------	------------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Earth Continuity	18/10/2008	0.136	ohm	Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	247	V	Information
Neutral Voltage	18/10/2008	8	V	Information
PE Conductor Current	18/10/2008	< 0.15	mA	Pass

Overall: Pass

Asset ID: 08028	Description: SUPER LEO LAMP	User: SPCL SA003	Test Instrument: W02-0416
-----------------	-----------------------------	------------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Earth Continuity	18/10/2008	0.16	ohm	Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	249	V	Information
Neutral Voltage	18/10/2008	8	V	Information
PE Conductor Current	18/10/2008	< 0.15	mA	Pass

Overall: Pass

Asset ID: 08029	Description: SUPER LEO LAMP	User: SPCL SA003	Test Instrument: W02-0416
-----------------	-----------------------------	------------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Earth Continuity	18/10/2008	0.168	ohm	Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	247	V	Information
Neutral Voltage	18/10/2008	8	V	Information
PE Conductor Current	18/10/2008	< 0.15	mA	Pass

Overall: Pass

Asset ID: 08030	Description: LAZER LAMP	User: SPCL SA003	Test Instrument: W02-0416
-----------------	-------------------------	------------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Earth Continuity	18/10/2008	0.064	ohm	Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	246	V	Information
Neutral Voltage	18/10/2008	8	V	Information
PE Conductor Current	18/10/2008	0.26	mA	Pass

Overall: Pass

Asset ID: 08031	Description: MIRROR BALL MOTOR	User: SPCL SA003	Test Instrument: W02-0416
-----------------	--------------------------------	------------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Earth Continuity	18/10/2008	0.152	ohm	Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	247	V	Information
Neutral Voltage	18/10/2008	8	V	Information
PE Conductor Current	18/10/2008	< 0.15	mA	Pass

Overall: Pass

Asset ID: 08032	Description: IEC POWER LEAD	User: SPCL SA003	Test Instrument: W02-0416
-----------------	-----------------------------	------------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
IEC Lead Continuity	18/10/2008	0.042	ohm	Pass

Detailed Latest Test Results

Test Status: All, Test Type: All



The Southern Pat Company Limited

Portable Appliance Test Engineers

Insulation Resistance 18/10/2008 > 199 MOhm Pass
IEC Lead Polarity 18/10/2008 Pass

Overall: Pass

Asset ID: 08033 Description: SMOKE UNIT User: SPCL SA003 Test Instrument: W02-0416

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Earth Continuity	18/10/2008	0.112	ohm	Pass
Insulation Resistance	18/10/2008	3	MOhm	Pass
Live Voltage	18/10/2008	248	V	Information
Neutral Voltage	18/10/2008	8	V	Information
PE Conductor Current	18/10/2008	< 0.15	mA	Pass

Overall: Pass

Asset ID: 08034 Description: PRO ATLANTIS LAMP User: SPCL SA003 Test Instrument: W02-0416

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Earth Continuity	18/10/2008	0.192	ohm	Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	248	V	Information
Neutral Voltage	18/10/2008	8	V	Information
PE Conductor Current	18/10/2008	< 0.15	mA	Pass

Overall: Pass

Asset ID: 08035 Description: NUMARK AC ADAPTER User: SPCL SA003 Test Instrument: W02-0416

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	247	V	Information
Neutral Voltage	18/10/2008	8	V	Information
Touch Current	18/10/2008	< 0.07	mA	Pass

Overall: Pass

Asset ID: 08036 Description: NUMARK MIXING UNIT User: SPCL SA003 Test Instrument: W02-0416

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	248	V	Information
Neutral Voltage	18/10/2008	8	V	Information
Touch Current	18/10/2008	< 0.07	mA	Pass

Overall: Pass

Asset ID: 08037 Description: AC POWER ADAPTER User: SPCL SA003 Test Instrument: W02-0416

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	249	V	Information
Neutral Voltage	18/10/2008	8	V	Information
Touch Current	18/10/2008	< 0.07	mA	Pass

Overall: Pass

Asset ID: 08038 Description: CLIP LAMP User: SPCL SA003 Test Instrument: W02-0416

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	247	V	Information
Neutral Voltage	18/10/2008	8	V	Information
Touch Current	18/10/2008	< 0.07	mA	Pass

Overall: Pass

Asset ID: 08039 Description: 6G EXT LEAD User: SPCL SA003 Test Instrument: W02-0416

Test Type	Date	Result	Unit	Status
Visual	18/10/2008			Pass
Earth Continuity	18/10/2008	0.058	ohm	Pass
Insulation Resistance	18/10/2008	> 199	MOhm	Pass
Live Voltage	18/10/2008	247	V	Information
Neutral Voltage	18/10/2008	7	V	Information
PE Conductor Current	18/10/2008	< 0.15	mA	Pass

Overall: Pass

Detailed Latest Test Results

Test Status: All, Test Type: All



The Southern Pat Company Limited

Portable Appliance Test Engineers

Total Tests: 39